



NOTES:

1. Factory installed plugs required whenever hydrants are installed in areas with high groundwater level, as determined by dewatering requirements and City Engineer. All nozzles should be painted black for all hydrants with plugged drain holes. Hydrants with no plugs shall be painted all red.
2. All ductile iron watermain fittings shall be fusion bonded epoxy coated.
3. Hydrants shall be marked with stainless steel tag from factory.
4. All watermain bolts shall be core-blue or approved equal.
5. Hydrants must be stamped for the year installed or up to one year previous.
6. Extensions are required on gate valves >8' deep.
7. Gate valve shall be installed in accordance with City Plate No. WAT-02.



STANDARD DETAILS  
HYDRANT

FARMINGTON, MINNESOTA

Last Revision:  
FEB 2017

City Plate No.  
WAT-01  
2017